


FILTER RATE BOTH CELLS (GPM)	BACKWASH RATE PER CELL (GPM)	FILTER AREA PER CELL (SQ. FT)	CATALOG NUMBER	SPACE REQUIREMENTS						INFLUENT CONN. EACH CELL (NPT)	EFFLUENT CONN. EACH CELL (NPT)			
				A	B	C	D	F NON-CODE	F CODE					
212	106	7.07	6723-V-2C	36"	78"	120"	58"	95.50"	96.38"	13	14	14	3"	3"
288	144	9.62	6724-V-2C	42"	90"	138"	64"	96.75"	98.00"	17	19	20	4"	4"
376	188	12.57	6725-V-2C	48"	102"	156"	70"	96.88"	101.13"	22	25	26	4"	4"
476	238	15.90	6726-V-2C	54"	114"	174"	76"	97.25"	102.88"	28	31	34	4"	4"
588	294	19.60	6727-V-2C	60"	126"	192"	82"	96.38"	104.50"	34	39	43	4"	4"
714	357	23.80	6728-V-2C	66"	138"	210"	88"	95.75"	106.13"	40	45	52	4"	4"
848	424	28.27	6729-V-2C	72"	150"	228"	92"	97.13"	107.88"	47	53	62	6"	6"
996	498	33.20	6730-V-2C	78"	162"	246"	98"	97.25"	109.63"	55	63	75	6"	6"
1154	577	38.48	6731-V-2C	84"	174"	264"	104"	101.50"	115.25"	64	73	89	6"	6"
1376	663	44.19	6732-V-2C	90"	186"	282"	110"	103.00"	117.00"	73	84	103	6"	6"
1508	754	50.26	6733-V-2C	96"	198"	300"	116"	115.88"	130.63"	102	114	137	6"	6"
1702	851	56.74	6734-V-2C	102"	210"	318"	122"	117.38"	132.38"	116	129	156	6"	6"
1908	954	63.61	6735-V-2C	108"	222"	336"	130"	119.00"	134.00"	130	145	175	8"	8"
2126	1063	70.88	6736-V-2C	114"	234"	354"	136"	120.63"	135.75"	144	161	196	8"	8"
2356	1178	78.54	6737-V-2C	120"	246"	372"	142"	122.50"	137.38"	160	179	218	8"	8"

15 GPM/SQ. FT.
MAX IS 20 GPM/SQ. FT.

* SHALLOW-DISHED HEADS



NOTE: LISTED FLOW RATE IS TO 20 GPM/SQ. FT. FILTER AREA

GENERAL NOTES:

1. TANK MATERIAL-316L STAINLESS STEEL
2. EXTERIOR SURFACES TO BE COATED WITH BLUE PAD-COTE, AN NSF LISTED CHEMICALLY CURED SEMI-GLOSS EPOXY.
3. INTERCONNECTING PIPING-SCH. 80 PVC, MAX. VELOCITY LESS THAN 10 FPS.
4. FILTER WORKING PRESSURE IS 50 PSI. TEST PRESSURE IS 65 PSI.
5. TANK WARRANTED AGAINST DEFECTS IN MATERIAL AND WORKMANSHIP PER SPECIFICATIONS.

CATALOG # 67 ___ - ___ - V - 2C - ___
(Verticel, 2-Cell Filter, ___" Dia.)
___ GPM Filter Capacity @ ___ GPM/SQ FT of Filter Area
Piping size ___ NPT



DESCRIPTION	TWO-CELL VERTICAL SAND FILTERS
JOB NAME & LOCATION	
CUSTOMER	
DWG/REV	2/28/06
SHEET 1 OF 1	REV
DWG. NO.	6723-6737

PADDOCK
POOL EQUIPMENT COMPANY
PO Box 11676 email@paddockpool.com (800)849-2729
Rock Hill, SC 29731-1676 Fax: (803)324-1116

SUBMITTAL DRAWING		
DISPOSITION	BY	DATE
APPROVED AS SUBMITTED		
APPROVED AS MODIFIED		
NOT APPROVED -- RESUBMIT		