

Paddock VGB Drain Cover Lifespan

1. **Requirement** – Inspect cover at 10 years minimum for any signs of damage and replace if needed. (Covers older than 10 years must be inspected every year thereafter for any damage compromising unit which would necessitate replacement.)
2. **Requirement** – Replace screws every 7 years at minimum (use only the size and grade of stainless steel screws 8/32 x ½" SS 316L recommended by Paddock).
3. **Recommendation** – Check covers and screws yearly – replace any covers or screws immediately that are compromised, damaged or broken in any way.
4. **VGB Covers** do not need to be replaced unless they are compromised, damaged or broken and all above requirements are met. These are stainless steel covers and should last life of facility if properly maintained. Ultraviolet light test which establishes life expectancy is for degradation of resin products such as PVC or plastics.

Examples of Paddock covers & sumps offered



2424PCFC VGB Cover



2020PCDC or 2424PCDC VGB Cover



2040PCGO or 2448PCFC VGB Cover



Paddock Sumps